



PLAN FOR 18" OR LESS PIPE



PLAN FOR PIPE GREATER
THAN 18" UP TO 24"

## NOTES:

- 1. ITEM 655.02 FRAME & GRATE- FRAME 2'-4 15/16 " X 3'-1 1/2" GRATE 2'-3 11/16 " X 3'-0 1/2" RECTANGULAR FRAME & GRATE ASSEMBLY TYPE ND. 11, SEE N.Y.S.D.O.T. STANDARD SHEETS SHEETS 655-4R1, 655-5R1, 655-6R1 AND 655-3. PAYMENT AREA = 7.2 SQ. FEET
- 2. REINFORCEMENT SHALL HAVE A COVER OF 2' UNLESS OTHERWISE SHOWN. THE COST OF ALL BAR REINFORCEMENT SHALL BE INCLUDED IN THE PRICE BID FOR DROP INLETS.
- 3. ALL CONCRETE FOR DROP INLETS SHALL BE CLASS "A".
  BENCHES SHALL BE CAST-IN-PLACE
  ON ALL STORM DROP INLETS REGARDLESS OF PIPE DIAMETER.
  COST TO BE INCLUDED IN DROP INLET ITEM.
- 4. WHEN CURB EXISTS AND CURB LANES ARE 13' OR LESS, THIS DETAIL SHALL APPLY.
- 5. THE INTERIOR AND EXTERIOR OF ALL DROP INLETS TO BE COATED WITH TWO COATS OF KOPPERS SUPER SERVICE BLACK OR APPROVED EQUAL.
- 6. ALL CONNECTIONS SHALL BE MADE WITH 100% MORTAR
- 7. INSIDE DIMENSTION SHALL BE 2'-0" OR 2'-8 1/2"
- 8. REFER TO FRAME & GRATE ANCHOR DETAIL



## DROP INLET TYPE "S" CAST-IN-PLACE W/ RECESSED CURB

NOT TO SCALE

2/2/04

REVISED